

MATERIAL REACTION TO FIRE CLASSIFICATION
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Delivered as an extension of certificate n°17-00826 L, valid until June 20th, 2022 expiration date of the first PV

CERTIFICATE N°17-00826-1 L

And appendices of 0 page

MATERIAL presented by: CREATION BAUMANN AG
Bern- Zürich Str. 23
4900 LANGENTHAL
SUISSE

TRADE NAME: GREEN OFFICE
SCRENO R

BRIEF DESCRIPTION: 100% polyester fabric with fireproofed coating phosphorus based
Nominal surface weight: 272 ± 10 g/m²
Nominal thickness: 0.45 ± 0.05 mm
Colours: various

TEST REPORT: N° 17-00826 E1-V1 on the June 20th, 2017

TESTS: Electrical burner test
Flame persistence test
Dripping test
Ageing in climatic room

CLASSIFICATION: **M 1**

**Classification valid for any application for which the product is not subjected
to the CE marking of the Construction products**

CLASSIFICATION DURATION (article 5 of appendix 2): Unlimited in indoor use, shielded from external weather conditions
(material no washable and not suitable for dry cleaning)

given the criteria resulting from the tests described in the enclosed test report.


The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the January 24th, 2019



Laure ATCHADE



Jean-Marc ORAISON

Engineer Tests and Trials

In charge of Fire Regulation